



KERATILE, S.L.U.

Pol. Ind. Casablanca. Calle del Ferrocarril, 4. 12593 Moncofar. Castellon, Spain . www.keratile.es

MODEL	ALEN TABACO		
SIZE	23x120		
GROUP	Bla		
TYPE	Glazed Porcelain Tile		
DESCRIPTION OF TEST	TEST VALUE	KERATILE	STANDARD
WATTER ABSORTION	AA<0,5%	Fulfilled	UNE-EN-ISO 10545-3
BREAKING STRENGTH	> 1300 N	Fulfilled	UNE-EN-ISO 10545-4
RESISTANCE OF FLEXION	> 35 N/mm2	Fulfilled	UNE-EN-ISO 10545-4
ABRASION	Class	PEI III	UNE-EN-ISO 10545-7
CRACKING RESISTANCE	Demanded	Fulfilled	UNE-EN-ISO 10545-11
FROST RESISTANCE	Demanded	Fulfilled	UNE-EN-ISO 10545-12
CHEMICAL RESISTANCE (Domestic products & swimming pool products)	Minimum GB	Fulfilled	UNE-EN-ISO 10545-13
RESISTANCE TO STAINS	Minimum class 3	Fulfilled	UNE-EN-ISO 10545-14
SLIP RESISTANCE	Available Method	Class 1	UNE-ENV 12633:2003
HARDNESS (MOHS)	Minimum 3	Fulfilled	EN 101